

Fireworks Stand Inspection Checklist

	A	B	C
1	Item	Reference	Violation
2	General Requirements	NFPA 1124 - 7.1.1	Retail sales of consumer fireworks in both new and existing buildings, structures, and facilities shall comply with the requirements of this chapter unless otherwise indicated.
3			
4			
5	Minimum Requirements	7.1.1.3	Existing life safety features that do not meet the requirements for new buildings but that exceed the requirements for existing buildings shall not be further diminished.
6	Modernization or Renovation	7.1.1.4	Any alteration or any installation of new equipment shall meet, as nearly as practicable, the requirements for new construction.
7		7.1.1.4.1	Only the altered, renovated, or modernized portion of an existing building, system, or individual component shall be required to meet the provisions of this code that are applicable to new construction. 7.1.1.4.2 If the alteration, renovation
8		7.1.1.4.2	If the alteration, renovation, or modernization adversely impacts required life safety features, additional upgrading shall be required.
9	Facility Classification	7.1.2(1)	(1) Permanent buildings and structures, including the following: (a) Stores (b) CFRS facilities
10	Facility Classification	7.1.2(2)	Temporary facilities, including the following: (a) CFRS stands (b) Tents (c) Canopies (d) Membrane structures
11	Special Limits on Retail Sales	7.2.1	Retail sales of consumer fireworks, including their related storage and display for sale of such fireworks, shall be in accordance with this code.
12		7.2.2	Retail sales of consumer fireworks shall be limited to mercantile occupancies defined in NFPA 101, Life Safety Code.
13		7.2.3	Any building or structure used for the retail sales of consumer fireworks, including their related storage, shall comply with NFPA 101, Life Safety Code, for mercantile occupancies, except as provided in this code.
14		7.2.4	Retail sales of display fireworks and pyrotechnic articles, including the related storage and display for sale of such fireworks and articles, shall be prohibited at a CFRS facility or store.
15		7.2.5	Retail sales of certain explosive devices prohibited by the Child Safety Act of 1966, including the related storage and display for sale of such devices, shall be prohibited at a CFRS facility or store.
16		7.2.6	The retail sales of pest control devices, including their related storage and display for sale, shall be prohibited at a CFRS facility or store.
17		7.2.7	The retail sales of fireworks that do not comply with the regulations of the U.S. Consumer Product Safety Commission as set forth in 16 CFR 1500 and 1507 and the regulations of the U.S. Department of Transportation as set forth in 49 CFR 100 to 178, including their related storage and display for sale, shall be prohibited.
18	General Requirements for All Retail Sales		

Fireworks Stand Inspection Checklist

	A	B	C
19	Exempt Amounts	7.3.1.1	The requirements of this chapter shall not apply to CFRS facilities or stores where the consumer fireworks are in packages and where the total quantity of consumer fireworks on hand does not exceed 125 lb (net) [56.8 kg] of pyrotechnic composition or, in a building protected throughout with an approved automatic sprinkler system installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, 250 lb (net) [113.6 kg] of pyrotechnic composition.
20		7.3.1.2	Where the actual weight of the pyrotechnic composition of consumer fireworks is not known, 25 percent of the gross weight of the consumer fireworks, including packaging, shall be permitted to be used to determine the weight of the pyrotechnic composition.
21	Permits	7.3.2	Where required by state or local laws, ordinances, or regulations, a permit for the following shall be obtained: (1) Construction, erection, or operation of the following: (a) Permanent building or structure (b) Temporary structure such as a stand, tent, or canopy used for the purpose of the retail display or sale of consumer fireworks to the public (2) Storage of consumer fireworks in connection with the retail display or sale of consumer fireworks to the public
22	Fire Department Access	7.3.4	Any portion of an exterior wall of a building, sidewall of a tent, or other defined perimeter of a CFRS facility or store shall be accessible within 150 ft (45.7 m) of a public way or an approved fire apparatus access.
23	Construction of Buildings and Structures	7.3.5	Consumer fireworks shall only be permitted to be sold at retail in any of the following buildings or structures, provided that any new building or structure does not exceed one story in height: (1) Permanent buildings or structures constructed in accordance with the building code enforced by the AHJ (2) Tents, canopies, or temporary membrane structures complying with NFPA 102, Standard for Grandstands, Folding and Telescopic Seating, Tents, and Membrane Structures (3) Temporary structures constructed in accordance with this chapter (4) Temporary CFRS stands greater than 800 ft ² (74 m ²) in area that also meet the requirements for a permanent structure (5) Vehicles, such as vans, buses, trailers, recreational vehicles, motor homes, travel trailers, trucks, and automobiles, complying with the applicable requirements for CFRS stands
24	Stands/Site Plans	7.6.1	The site plan for stands shall show the location of the stand on the site and indicate the minimum separation distances required by 7.4.7.
25	Stands/Temporary Stands	7.6.2.1	Temporary CFRS stands of less than 200 ft ² (18.6 m ²) shall be required to have only one portable fire extinguisher.
26	Stands/Temporary Stands	7.6.2.2	An approved fire safety and evacuation plan shall not be required for temporary CFRS stands.
27	Stands/Temporary Stands	7.6.2.3.1	Retail sales areas within temporary CFRS stands shall have a minimum of two exits.
28	Stands/Temporary Stands	7.6.2.3.2	Exits provided for temporary fireworks retail sales stands shall be located such that the maximum egress travel distance as measured from the most remote point to an exit along the natural and unobstructed path of egress travel does not exceed 35 ft (10.6 m).

Fireworks Stand Inspection Checklist

	A	B	C
29	Stands/Temporary Stands	7.6.2.3.3	Customers shall not be permitted inside a temporary CFRS stand unless it complies with the means of egress requirements in 7.3.14.
30	Stands/Temporary Stands	7.6.2.3.4	Exit signs shall not be required to be illuminated in stands that are not open for business after dusk, or in temporary CFRS stands where the interior is not accessible to the public.
31	Stands/Temporary Stands	7.6.2.3.5	Emergency lighting shall not be required in stands that are not open for business after dusk or for temporary CFRS stands where the interior is not accessible to the public.
32	Stands/Temporary Stands	7.6.3	Temporary CFRS stands shall be separated from adjacent buildings and structures in accordance with Table 7.4.7.2.
33	Stands Not Open to the Public.	7.6.4.1	In temporary CFRS stands where the interior is not accessible to the public, the minimum clear width of the aisle shall be permitted to be not less than 28 in. (710 mm).
34	Stands Not Open to the Public.	7.6.4.2.1	Egress doors provided for temporary CFRS stands where the interior is not accessible to the public shall be permitted to be not less than 28 in. (710 mm) in width.
35	Stands Not Open to the Public.	7.6.4.2.2	For temporary CFRS stands where the interior is not accessible to the public, latching devices on doors shall be permitted without panic hardware.
36	Stands Not Open to the Public.	7.6.4.3	In temporary CFRS stands where the interior is not accessible to the public, the maximum height of sales displays shall be limited to 8 ft (2.44 m).
37	Stands Not Open to the Public.	7.6.4.4	Temporary CFRS stands where the interior is not accessible to the public shall not be required to comply with 7.3.15.3.
38	Stands Not Open to the Public.	7.6.4.5	Individual consumer fireworks items displayed for sale in temporary CFRS stands where the interior is not accessible to the public shall not be required to have covered fuses.
39	Stands Not Open to the Public.	7.6.4.6	The following shall apply to the sales display of consumer fireworks in temporary CFRS stands that do not allow access to the interior of the stand by the public: (1) Consumer fireworks shall be displayed in a manner that prevents the fireworks from being handled by persons other than those operating, supervising, or working in the temporary CFRS stand. (2) The handling requirements of 7.6.4.6(1) shall not apply to packaged assortments, boxes, or similarly packaged containers of one or more items, regardless of type