



South Carolina Building Codes Council

PO Box 11329
Columbia, SC 29211-1329

Request for Statewide Code Modification

Jurisdiction or Organization: <u>Building Official's Association of SC</u>	
Representative: <u>Buddy Skinner</u>	Title: <u>President</u>
Address: <u>PO Box 12220, Columbia, SC, 29211</u>	
Phone: <u>864-467-4553</u>	E-mail: <u>bskinner@greenville.gov</u>
Signature: <u><i>Buddy Skinner</i></u>	Date: <u>5/24/18</u>

Code: <u>Modification IBC 2015 06</u>	Edition: <u>2015</u>	Section: <u>IBC 1016.2</u>
Check One: <input type="checkbox"/> Delete and substitute the following <input checked="" type="checkbox"/> Delete without substitution <input type="checkbox"/> Add the following <input type="checkbox"/> Modify the following Type or print proposed modification. Use additional pages if necessary. <u>Underline New language.</u> Line-Through Deleted Language.		
Means of egress shall consist of continuous and unobstructed paths of travel to the exterior of a building. Means of egress shall not be permitted through kitchens, closets, restrooms and similar areas nor through adjacent tenant spaces.		
Exception: Means of egress shall be permitted through a kitchen area serving adjoining rooms constituting part of the same dwelling unit or guest room.		
When unusually hazardous conditions exist, the building official may require additional means of egress to assure the safety of the occupants.		

Reason: <input type="checkbox"/> Unusually Restrictive <input type="checkbox"/> Impractical <input checked="" type="checkbox"/> Threat to Human Injury or Life Safety
Type or print the reason for the proposed modification. Use additional pages if necessary.
This is a strike and add modification to the code.
This modification affected the whole code section and deleted some critical information for exiting through intervening spaces. A new code modification will be submitted to properly address the concern stated in this previous code change.

Email Form Button