



South Carolina Department of Labor, Licensing and Regulation  
**South Carolina Building Codes Council**  
 P.O. Box 11329 • Columbia, SC 29211  
 110 Centerview Dr. Columbia, SC 29210  
 Phone: 803-896-4688 Fax: 803-896-4814  
 www.llr.sc.gov/POL/BCC/



## Request for Statewide Code Modification

**Jurisdiction or Organization:** Chester Fire Department / BOASC

**Representative:** Don Wood **Title:** Fire Marshal

**Address:** 156 Columbia St., Chester SC 29706

**Phone:** 803-385-2123 **E-mail:** dwood@chesterfiredept.com

**Signature:** *Don Wood* **Date:** 05/01/2018

**Code:** SC Modification IFC 2015 06 **Edition:** 2015 **Section:** IFC 905.3

**Check One:**  Delete and substitute the following  Delete without substitution  Add the following  Modify the following  
 Type or print proposed modification. Use additional pages if necessary. Underline New language. ~~Line Through Deleted Language.~~

~~Modification Number: IFC 2015 06.~~  
~~Section: 905.3 Required installations. Modification: Added Exception 2 to the section.~~  
~~The additional exception states: 1. Standpipe systems are not required in Group R-3 occupancies.~~  
~~2. Where a standpipe system is provided per section 905, the hose and nozzle may be removed if approved by the AHJ.~~  
~~Reason: To improve fire department operations.~~  
~~Note: Continued modification IFC 2012 06.~~  
~~Proponent: South Carolina Fire Marshal's Association.~~  
~~Effective Date: July 1, 2013.~~

**Reason:**  Unusually Restrictive  Impractical  Threat to Human Injury or Life Safety  
 Type or print the reason for the proposed modification. Use additional pages if necessary.

Authorization to approve removal of existing occupant-use hose lines has been added to the International Fire Code 2018 edition Section 901.8.2.