



South Carolina Department of Labor, Licensing and Regulation

### South Carolina Building Codes Council

P.O. Box 11329 • Columbia, SC 29211  
110 Centerview Dr. Columbia, SC 29210  
Phone: 803-896-4688 Fax: 803-896-4814  
www.llr.sc.gov/POL/BCC/



## Request for Statewide Code Modification

**Jurisdiction or Organization:** Chester Fire Department / BOASC

**Representative:** Don Wood **Title:** Fire Marshal

**Address:** 156 Columbia St., Chester SC 29706

**Phone:** 803-385-2123 **E-mail:** dwood@chesterfiredept.com

**Signature:** *Buddy Skisner* **Date:** 05/24/2018

**Code:** Modification IFC 2015 07 **Edition:** 2015 **Section:** IFC 906.1

**Check One:**  Delete and substitute the following  Delete without substitution  Add the following  Modify the following  
Type or print proposed modification. Use additional pages if necessary. Underline New language. ~~Line Through Deleted Language.~~

~~Modification Number: IFC 2015 07.~~  
~~Section: 906.1(1) Where required.~~  
~~Modification: The "Exception" was deleted without substitution.~~  
~~Reason: The exception grants a "trade-off" in favor of quick response sprinklers in several occupancies.~~  
~~Note: Continued modification IFC 2006 0 and IFC 2012 07. Proponent: Fire Equipment Manufacturer's Association.~~  
~~Effective Date: July 1, 2008.~~

**Reason:**  Unusually Restrictive  Impractical  Threat to Human Injury or Life Safety  
Type or print the reason for the proposed modification. Use additional pages if necessary.

The exception that allows trade-off in favor of quick response sprinklers in several occupancies is no longer in the International Fire Code 2018 edition.