



South Carolina Department of Labor, Licensing and Regulation
South Carolina Building Codes Council
 P.O. Box 11329 • Columbia, SC 29211
 110 Centerview Dr. Columbia, SC 29210
 Phone: 803-896-4688 Fax: 803-896-4814
 www.llr.sc.gov/POL/BCC/



Request for Statewide Code Modification

Jurisdiction or Organization: Chester Fire Department / BOASC

Representative: Don Wood Title: Fire Marshal

Address: 156 Columbia St., Chester SC 29706

Phone: 803-385-2123 E-mail: dwood@chesterfiredept.com

Signature: *Don Wood* Date: 05/01/2018

Code: SC Modification IFC 2015 09 Edition: 2015 Section: IFC 2307.4

Check One: Delete and substitute the following Delete without substitution Add the following Modify the following
 Type or print proposed modification. Use additional pages if necessary. Underline New language. Line Through Deleted Language.

Delete: ~~SC Modification IFC 2015 09~~

Add: 2307.4 Location of dispensing operations and equipment.
 The point of transfer for LP-gas dispensing operations shall be separated from buildings and other exposures in accordance with the following: NFPA 58 Table 6.7.2.1 and IFC Section 2306.7.

- ~~1. Not less than 25 feet (7620 mm) from buildings where the exterior wall is not part of a fire resistance-rated assembly having a rating of 1 hour or greater.~~
- ~~2. Not less than 25 feet (7620 mm) from combustible overhangs on buildings, measured from a vertical line dropped from the face of the overhang at a point nearest the point of transfer.~~
- ~~3. Not less than 25 feet (7620 mm) from the lot line of property that can be built on.~~
- ~~4. Not less than 25 feet (7620 mm) from the centerline of the nearest mainline railroad track.~~
- ~~5. Not less than 10 feet (3048 mm) from public streets, highways, thoroughfares, sidewalks and driveways.~~
- ~~6. Not less than 10 feet (3048 mm) from buildings where the exterior wall is part of a fire resistance-rated assembly having a rating of 1 hour or greater.~~

Exception: The point of transfer for LP-gas dispensing operations need not be separated from canopies that are constructed in accordance with the International Building Code and that provide weather protection for the dispensing equipment.
LP-gas containers shall be located in accordance with Chapter 61. LP-gas storage and dispensing equipment shall be located outdoors and in accordance with Section 2306.7.

Reason: Unusually Restrictive Impractical Threat to Human Injury or Life Safety
 Type or print the reason for the proposed modification. Use additional pages if necessary.

To bring IFC Chapter 23 in harmony with NFPA 58 by using the existing table in it's entirety.