



South Carolina Department of Labor, Licensing and Regulation
South Carolina Building Codes Council
 P.O. Box 11329 • Columbia, SC 29211
 110 Centerview Dr. Columbia, SC 29210
 Phone: 803-896-4688 Fax: 803-896-4814
 www.llr.sc.gov/POL/BCC/



Request for Statewide Code Modification

Jurisdiction or Organization: Chester Fire Department / BOASC

Representative: Don Wood **Title:** Fire Marshal

Address: 156 Columbia St., Chester SC 29706

Phone: 803-385-2123 **E-mail:** dwood@chesterfiredept.com

Signature: *Buddy Skues* **Date:** 05/24/2018

Code: Modification IFC 2015 10 **Edition:** 2015 **Section:** IFC 2307.6.4

Check One: Delete and substitute the following Delete without substitution Add the following Modify the following
 Type or print proposed modification. Use additional pages if necessary. Underline New language. Line Through Deleted Language.

Modification Number: ~~IFC 2015 10-Section: 2307.6.4 Vehicle impact protection~~
Modification: ~~An exception was added to the section.~~
The new exception states: ~~Exception: An alternative method may be used that meets the intent of this section with the approval of the AHJ.~~
Reason: ~~NFPA 58 requires protection from vehicular impact in a manner to be approved by the authority having jurisdiction.~~
Note: ~~Continued modification IFC 2012 10 (Old Section was 2307.5.3)~~
Proponent: ~~South Carolina Propane Gas Association.~~
Effective Date: ~~July 1, 2013.~~

Reason: Unusually Restrictive Impractical Threat to Human Injury or Life Safety
 Type or print the reason for the proposed modification. Use additional pages if necessary.

The provision for alternative method for vehicle impact protection is currently allowed in 2018 International Fire Code Section 312.3