



South Carolina Department of Labor, Licensing and Regulation
South Carolina Building Codes Council
 P.O. Box 11329 • Columbia, SC 29211
 110 Centerview Dr. Columbia, SC 29210
 Phone: 803-896-4688 Fax: 803-896-4814
 www.llr.sc.gov/POL/BCC/



Request for Statewide Code Modification

Jurisdiction or Organization: Chester Fire Department / BOASC

Representative: Don Wood **Title:** Fire Marshal

Address: 156 Columbia St., Chester SC 29706

Phone: 803-385-2123 **E-mail:** dwood@chesterfiredept.com

Signature: *Buddy Skinner* **Date:** 05/24/2018

Code: Modification IFC 2015 15 **Edition:** 2015 **Section:** IFC 6105.2

Check One: Delete and substitute the following Delete without substitution Add the following Modify the following
 Type or print proposed modification. Use additional pages if necessary. Underline New language. ~~Line Through Deleted Language.~~

Modification Number: ~~IFC 2015 15.~~
Section: ~~6105.2 Release to the atmosphere.~~
Modification: ~~To refer to NFPA 58.~~
The section now states: ~~LP gas shall not be released to the atmosphere, except as provided in NFPA 58 7.3.1.~~
Reason: ~~NFPA 58 7.3.1 lists eight allowable methods of venting LP gas.~~
Note: ~~Continued modification IFC 2012 15.~~
Proponent: ~~South Carolina Fire Marshal's Association.~~
Effective Date: ~~July 1, 2013.~~

Reason: Unusually Restrictive Impractical Threat to Human Injury or Life Safety
 Type or print the reason for the proposed modification. Use additional pages if necessary.

The provision for release of LP-Gas to the atmosphere has been added in 2018 International Fire Code Section 6105.2