



South Carolina Department of Labor, Licensing and Regulation  
**South Carolina Building Codes Council**  
 P.O. Box 11329 • Columbia, SC 29211  
 110 Centerview Dr. Columbia, SC 29210  
 Phone: 803-896-4688 Fax: 803-896-4814  
 www.llr.sc.gov/POL/BCC/



## Request for Statewide Code Modification

**Jurisdiction or Organization:** Chester Fire Department / BOASC

**Representative:** Don Wood **Title:** Fire Marshal

**Address:** 156 Columbia St., Chester SC 29706

**Phone:** 803-385-2123 **E-mail:** dwood@chesterfiredept.com

**Signature:** *Buddy Skinner* **Date:** 05/24/2018

**Code:** Modification IFC 2015 20 **Edition:** 2015 **Section:** IFC 6109.7

**Check One:**  Delete and substitute the following  Delete without substitution  Add the following  Modify the following  
 Type or print proposed modification. Use additional pages if necessary. Underline New language. ~~Line Through Deleted Language.~~

**Modification Number:** ~~IFC-2015-20.~~  
**Section:** ~~6109.7 Storage in basement, pit or similar location.~~  
**Modification:** ~~Modified the exception to increase the capacity of LP gas containers.~~  
~~The exception now states: Department of Transportation (DOT) specification cylinders with a maximum water capacity of 2.7 pounds (1.2 kg) for use in completely self-contained hand torches and similar applications. The quantity of LP gas shall not exceed 20 pounds (9 kg).~~  
**Reason:** ~~To be in harmony with NFPA 58 for one pound cylinders.~~  
**Note:** ~~Continued modification IFC 2012 20~~  
**Proponent:** ~~South Carolina Fire Marshal's Association.~~  
**Effective Date:** ~~July 1, 2013.~~

**Reason:**  Unusually Restrictive  Impractical  Threat to Human Injury or Life Safety  
 Type or print the reason for the proposed modification. Use additional pages if necessary.

Modified provision is updated in 2018 edition of the International Fire Code section 6109.7