



South Carolina Department of Labor, Licensing and Regulation
South Carolina Building Codes Council
 P.O. Box 11329 • Columbia, SC 29211
 110 Centerview Dr. Columbia, SC 29210
 Phone: 803-896-4688 Fax: 803-896-4814
 www.llr.sc.gov/POL/BCC/



Request for Statewide Code Modification

Jurisdiction or Organization: Chester Fire Department / BOASC

Representative: Don Wood **Title:** Fire Marshal

Address: 156 Columbia St., Chester SC 29706

Phone: 803-385-2123 **E-mail:** dwood@chesterfiredept.com

Signature: *Buddy Skinner* **Date:** 05/24/2018

Code: Modification IFC 2015 21 **Edition:** 2015 **Section:** IFC 6109.9

Check One: Delete and substitute the following Delete without substitution Add the following Modify the following
 Type or print proposed modification. Use additional pages if necessary. Underline New language. Line-Through Deleted Language.

~~Modification Number: IFC 2015 21.~~
~~Section: 6109.9 Storage within buildings accessible to the public.~~
~~Modification: Increased the capacity of LP-gas self-contained hand torches.~~
~~The section now states: Department of Transportation (DOT) specification cylinders with a maximum water capacity of 2.7 pounds (1.2 kg) used in completely self-contained hand torches and similar applications are allowed to be stored or displayed in a building accessible to the public. The quantity of LP-gas shall not exceed 200 pounds (91 kg) except as provided in Section 6109.11.~~
~~Reason: To be in harmony with NFPA 58 for one-pound cylinders.~~
~~Note: Continued modification IFC 2012 21~~
~~Proponent: South Carolina Fire Marshal's Association.~~
~~Effective Date: July 1, 2013.~~

Reason: Unusually Restrictive Impractical Threat to Human Injury or Life Safety
 Type or print the reason for the proposed modification. Use additional pages if necessary.

Modified provision is updated in 2018 edition of the International Fire Code section 6109.9