



South Carolina Department of Labor, Licensing and Regulation  
**South Carolina Building Codes Council**  
 P.O. Box 11329 • Columbia, SC 29211  
 110 Centerview Dr. Columbia, SC 29210  
 Phone: 803-896-4688 Fax: 803-896-4814  
 www.llr.sc.gov/POL/BCC/



## Request for Statewide Code Modification

**Jurisdiction or Organization:** City of Charleston – Charleston Fire Department

**Representative:** Mike Julazadeh **Title:** Chief Fire Marshal

**Address:** 2 George Street Charleston, SC 29401

**Phone:** (843) 724-3429 **E-mail:** JULAZADEHM@charleston-sc.gov

**Signature:** *Michael A. Julazadeh* **Date:** 5/30/2018

**Code:** International Fire Code **Edition:** 2018 **Section:** 507.3

**Check One:**  Delete and substitute the following  Delete without substitution  Add the following  Modify the following  
 Type or print proposed modification. Use additional pages if necessary. Underline New language. ~~Line Through Deleted Language.~~

**507.3 Fire flow.** Fire –flow requirements for buildings or portions of buildings and facilities shall be determined by an approved method acceptable to the Fire Code Official.

**Reason:**  Unusually Restrictive  Impractical  Threat to Human Injury or Life Safety

The current code does not identify acceptable methods to determine the fire flow. The purpose of this modification is to clarify the method must be acceptable to the Fire Code Official.