



# South Carolina Building Codes Council

PO Box 11329  
Columbia, SC 29211-1329


## Request for Statewide Code Modification

Jurisdiction or Organization: Dorchester County

Representative: Lisa Simmons Title: Building Inspector

Address: 500 North Main Street Box 3; Summerville, SC 29483

Phone: (843) 832-0011 E-mail: lsimmons2@dorchestercountysc.gov

Signature:  Date: 12/13/17

Code: R314.3 Locations Edition: 2018 Section: R314 Smoke Alarms

Check One:  Delete and substitute the following  Delete without substitution  Add the following  Modify the following  
Type or print proposed modification. Use additional pages if necessary. Underline New language. ~~Line-Through-Deleted-Language.~~

#5 Inside each room located on the second floor of a detached garage or accessory structure when supplied with power.

Reason:  Unusually Restrictive  Impractical  Threat to Human Injury or Life Safety  
Type or print the reason for the proposed modification. Use additional pages if necessary.

Area could easily be occupied for habitable space or used for sleeping purposes.