



South Carolina Building Codes Council

PO Box 11329
Columbia, SC 29211-1329


Request for Statewide Code Modification

Jurisdiction or Organization: Dorchester County

Representative: Lisa Simmons Title: Building Inspector

Address: 500 North Main Street Box 3; Summerville, SC 29483

Phone: (843) 832-0011 E-mail: lsimmons2@dorchestercountysc.gov

Signature:  Date: 12/13/17

Code: R315.3 Location Edition: 2018 Section: R315 Carbon Monoxide Alarms

Check One: Delete and substitute the following Delete without substitution Add the following Modify the following
Type or print proposed modification. Use additional pages if necessary. Underline New language. ~~Line Through Deleted Language.~~

R315.3 Location. Carbon monoxide alarms in dwelling units shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms. Carbon Monoxide alarms shall be installed inside each room located on the second floor of a detached garage or accessory structure when supplied with power. Where a fuel-burning appliance is located within a bedroom or its attached bathroom, a carbon monoxide alarm shall be installed within the bedroom.

Reason: Unusually Restrictive Impractical Threat to Human Injury or Life Safety
Type or print the reason for the proposed modification. Use additional pages if necessary.

Area could easily be occupied for habitable space or used for sleeping purposes.